




**BALTIMORE  
AIRCOIL COMPANY**



## **TRF TrilliumSeries™ Adiabatic Cooler Once Through Mode**

### **SOFTWARE INSTRUCTIONS**






# Table of contents

## SOFTWARE INSTRUCTIONS

<b>1</b>	<b>Scope</b>	<b>3</b>
	Once Through execution	3
<b>2</b>	<b>Control Logic</b>	<b>4</b>
	Self-contained mode	4
	Customer input mode	5
<b>3</b>	<b>Programmable logic controller</b>	<b>7</b>
	Programmable Logic Controller (PLC)	7
<b>4</b>	<b>Software</b>	<b>8</b>
	Overview menu	8
	HMI header	10
	Home	10
	Fans	11
	Setpoints	14
	Input & Output	20
	Alarms	24
	Settings	24
<b>5</b>	<b>Alarms and Warnings overview</b>	<b>28</b>
	Alarms overview	28
	Alarm codes	37
<b>6</b>	<b>Further Assistance &amp; Information</b>	<b>46</b>
	More information	46
	The service expert for BAC equipment	46

## Once Through execution

The TRF is a V-shaped dry cooler equipped with **adiabatic pre-coolers (1)** that cool the warm **process fluid (2)** by sensible heat transfer. **Water flows (3)** evenly over evaporative cooling pads located in front of the **dry finned coil (4)**. At the same time **axial (5) fans** draw **air (6)** through the pads where a portion of the water evaporates and cools down the saturated air. This increases the cooling capacity of the incoming air for cooling the process **fluid (7)** inside the coil.



# CONTROL LOGIC

tamb: ambient temperature

SWP1, SWP2: ambient temperature switchpoints


CWV: adiabatic pre-cooler city water valve

DV: adiabatic pre-cooler drain valve

## Self-contained mode

The PLC controls the fan speed based on the actual fluid outlet temperature and the set point, ensuring a minimum electrical consumption and noise level.

The PLC will activate and deactivate the adiabatic pre-coolers, one by one, based on a logical combination of fan speed and an ambient temperature switch point.



$T_{out}$ : process fluid outlet temperature

$T_{sp}$ : process fluid temperature set point

$T_{amb}$ : ambient dry bulb temperature

PID output: calculated signal based on  $T_{out}$  and  $T_{sp}$

CR: control range -  $dT$  to prevent hunting

Ad SWP: adiabatic switch point - ambient dry bulb temperature at which pre-cooling is allowed


All temperatures are adjustable via the set points menu. The PLC continuously measures the fluid outlet temperature via a temperature sensor installed in the fluid outlet pipe. The ambient temperature is measured via a temperature sensor that is factory installed on the unit. The PLC is pre-programmed and ready for operation. However, depending on the size of the installation, you may need to adjust the pre-programmed parameters during start-up.



## Customer input mode

The PLC controls the fan speed based on a customer provided signal.

The PLC will activate and deactivate the adiabatic pre-coolers, one by one, based on a logical combination of fan speed and an ambient temperature switch point.



$T_{out}$ : process fluid outlet temperature

$T_{sp}$ : process fluid temperature set point

$T_{amb}$ : ambient dry bulb temperature

SHL: speed high limit

SLL: speed low limit

PID output: calculated signal based on  $T_{out}$  and  $T_{sp}$

CR: control range -  $dT$  to prevent hunting

Ad SWP: adiabatic switch point - ambient dry bulb temperature at which pre-cooling is allowed

**CAUTION**

Changing the PLC's parameters may result in an undesired operation of the unit such as a hunting phenomenon, premature activation of pre-cooling (hence increased water consumption) or in late pre-cooling activation resulting in fluid outlet temperatures exceeding the design temperature.

# PROGRAMMABLE LOGIC CONTROLLER

## Programmable Logic Controller (PLC)

The PLC with built-in display:



The manual is valid for the following program version:

Software version: T3.3.0.26

Control version: 1.19



TRF

## SOFTWARE

### Overview menu


The screen or Human Interface Machine (HMI) is divided into 4 sections:

HMI header (top)

Main menu (bottom)

Sub menu (left)

Information section (right)



Menu	Function
Home	Unit overview, system messages
Fans	Overview Analog data Fan alarms Manuals

Menu	Function
Setpoints	Leaving fluid control Load limiting Maintenance
Input/Output	Temperatures Make up Starts and hours Manual
Alarms	
Settings	Set up Software version Technician



## HMI header



The HMI header contains:

- enable/disable the run authorization
- unit status (on/off)
- system date/time info
- unit serial number
- currently logged on user role and log in / log out button

There are various access levels to choose from:

- User (not password protected)
- Technician: username (Tech) & password (4734)

## Home

The main home screen shows information with regard to the overall unit status. The system message can show a number of messages, explained below the picture.



<b>Water usage disabled</b>	indicates if the water usage mode disabled mode is active or not during this mode, the unit is forced to operate dry
<b>Night quiet mode active</b>	indicates if the night quiet mode disabled mode is active or not during this mode, the maximum fan speed is limited
<b>Night dry mode active</b>	indicates if the night dry mode disabled mode is active or not during this mode, the unit is forced into dry mode overnight
<b>Emergency mode active</b>	indicates if the emergency mode is active or not during this mode, the fan speed is no longer controlled by the PLC but rather fixed at a pre-defined level.

# Fans



This menu provides information about parameters and lets you set certain parameters for the fans. You can do this either for all fans simultaneously by selecting the unit on the left, or individually by selecting a specific fan on the right.




The following sub menu's are available for both all fans & individual fans:

- overview
- analog data
- fan alarms
- manual

## Overview

Here you can set the maximum fan speed (the fans will never run faster as the value that is indicated here) as well as the emergency speed (speed at which the fans will run in case of loss of communication).



The 'average fan speed' is only available in the All Fans overview, not when you have selected a specific fan.



## Analog data

Overview	All Fans					
Analogy Data	Actual Speed	0	RPM	Current Set Value	0	RPM
	DC Link Voltage	0	V	Enable/Disable State	Disabled	
	DC Link Current	0.0	A	Current Power	0	W
	Module Temp.	0	°C	Operating Hours	0	
	Motor Temp.	0	°C			
Manual	Current Rotation	Reverse				

## Fan alarms

This provides an overview of the possible alarms. There are 2 possible statuses. A red dot indicates an alarm is active, a green dot indicates all is well.

Overview	All Fans		
Analogy Data	Current Limit Active	DC Link Voltage Low	
Fan Alarms	Line Impedance High	Braking Mode	
	Power Limit Active	Rotor Cal. In Prog.	
	Output Temp High	Low Speed	
	Motor Temp High	Open Circuit At AI	
	Elect. Temp High	DC Link Voltage High	
	<a href="#">&lt; Previous</a>	Page 1 of 2	<a href="#">Next &gt;</a>

## Manual

The manual menu allows to override the fan speed, rotation direction and to read out the Modbus address.



To change a Modbus address, refer to Settings, Technician menu.



The screenshot shows a control panel for a fan. On the left, a vertical menu lists "Overview", "Analog Data", "Fan Alarms", and "Manual". A blue vertical bar highlights the "Manual" option. The main area is titled "Fan 1" and contains the following controls:

- Manual Setpoint:** A numeric input field showing "0" with a "%" symbol to its right.
- Direction:** A dropdown menu showing "FWD".
- Set To Reverse:** A blue button.
- Fan Operation:** Three buttons: "Start", "Stop", and "Reset".
- Modbus Address:** A numeric input field showing "1".
- Manual Mode:** A toggle switch set to "Off".

The Modbus address is only available for a specific fan, not when you have selected "All Fans".  
Set manual mode to "off", if normal operation needs to be resumed.



# Setpoints

With the parameters that can be set in this menu, the user can finetune the behaviour of the unit.

## Leaving fluid control

This menu is only available if the control type in the relevant settings menu is set to "leaving fluid temperature control". This value depends on how the unit is physically configured.

The "leaving fluid temperature control" mode allows the user to program a process fluid temperature set point in which case the unit will independently operate to achieve this temperature.

## Customer input control

This menu is only available if the control type in the relevant Settings menu is set to "customer input". This value depends on how the unit is physically configured.

<b>Customer Input Control</b>	Operating Mode:	Energy Saver
	Signal Type:	Digital Input °C
<b>Load Limiting</b>	Adiabatic Switchpoint	38 °C
<b>Maintenance</b>	Run Authorization Type	Digital Input

<b>Operating mode</b>	determines the balance between energy and water usage. This can be set to either default, energy saver or water saver. Switching these modes will revert the parameters in the table below to their pre-programmed settings.
<b>Signal type</b>	defines the type of input signal. This can be set to either 4-20mA, 0-10V, 10-0V or BMS 0-100%. The current signal is supplied to input card EL3014 channel 2 or contacts X7:27 and X7:28. The voltage signal is supplied to input card EL3174 channel 1 or contacts X7:17 and X7:18. The BMS signal refers to the "CIFanCMD" variable in the BMS communications table.
<b>Adiabatic switchpoint</b>	ambient temperature at which adiabatic operation becomes possible
<b>Run authorization type</b>	source signal to switch the unit between stand-by and active. This can be set to either HMI, digital input or BMS. HMI refers to the button on the top left of the screen, digital input refers to input card EL1008 channel 6 or contacts X5:7 and X5:8 on the terminal strip, BMS refers to the "BMSrunEn" variable in the BMS communication table. The HMI button is always taken into account to enable the unit to run (also when the type is set to digital input or BMS).

Variable	Default	Energy Saver	Water saver
Control range	2.0 °C	0.5 °C	5.5 °C
Adiabatic switchpoint	X	X - 5.5 °C	X
Stage timer	120 sec	60 sec	300 sec

### Operating mode pre-programmed parameters

## Load limiting

Night quiet mode allows to limit the maximum fan speed. A lower adiabatic switchpoint can be programmed. Also, this can be used to make up for the reduced available thermal performance.

<b>Night quiet</b>	allows to either enable or disable the feature. If enabled, the "max fan speed" and "adiabatic switchpoint" parameters will become active during the times set in the schedule on page 2.
<b>Night quiet override</b>	if enabled, the "max fan speed" and "adiabatic switchpoint" parameters will become active regardless of the schedule on page 2. In addition to the on-screen button, the override can also be enabled with the "NightQuietOverride" variable in the BMS communication table.
<b>Max fan speed</b>	maximum fan speed that needs to be observed when "night quiet" mode is active
<b>Adiabatic switchpoint</b>	reduced ambient temperature at which adiabatic operation becomes possible. This second (reduced versus the standard) adiabatic switchpoint allows adiabatic operation at lower ambient temperatures in order to make up for the lower available thermal performance due to the lower fan speed.

Night quiet schedule allows to programme the night hours during which this mode becomes active when enabled at page 1.



Leaving Fluid Control	<b>Night Quiet Schedule</b> Sun to Mon: 21:00 - 06:00 Mon to Tue: 21:00 - 06:00 Tue to Wed: 21:00 - 06:00 Wed to Thu: 21:00 - 06:00 Thu to Fri: 21:00 - 06:00 Fri to Sat: 21:00 - 06:00 Sat to Sun: 21:00 - 06:00
Load Limiting	<input type="button" value="Sun to Mon"/> <input type="button" value="▼"/> <input type="button" value="21:00"/> - <input type="button" value="06:00"/> <input type="button" value="Update Schedule"/>
Maintenance	<input type="button" value="&lt; Previous"/> Page 2 of 6 <input type="button" value="Next &gt;"/>

Night dry allows to prevent the use of water and hence adiabatic operation between a time on one day and another the next day.

Leaving Fluid Control	<b>Night Dry</b> Night Dry ● Disabled <input type="button" value="Enable"/> <input checked="" type="button" value="Night Dry Override"/> Enabled <input type="button" value="Disable"/>
Load Limiting	
Maintenance	<input type="button" value="&lt; Previous"/> Page 3 of 6 <input type="button" value="Next &gt;"/>

<b>Night dry</b>	allows to either enable or disable the feature. If enabled, no water will be used during the times set in the schedule on page 4.
<b>Night dry override</b>	if enabled, no water will be used regardless of the schedule on page 4. In addition to the on-screen button, the override can also be enabled with the "NightDryOverride" variable in the BMS communication table.

Night dry schedule allows to program the night times during which this mode becomes active when enabled at page 3.

<b>Leaving Fluid Control</b>  <b>Load Limiting</b>  <b>Maintenance</b>	<p><b>Night Dry Schedule</b></p> <p>Sun: 21:00 - 06:00 Mon: 21:00 - 06:00 Tue: 21:00 - 06:00 Wed: 21:00 - 06:00 Thu: 21:00 - 06:00 Fri: 21:00 - 06:00 Sat: 21:00 - 06:00</p> <div style="text-align: center; margin-top: 10px;"> <span style="border: 1px solid #ccc; padding: 5px; border-radius: 5px;">Sun</span> ▾  <span style="border: 1px solid #ccc; padding: 5px; border-radius: 5px;">21:00</span> - <span style="border: 1px solid #ccc; padding: 5px; border-radius: 5px;">06:00</span>  <span style="background-color: #0070C0; color: white; border: none; padding: 5px; border-radius: 5px; font-weight: bold;">Update Schedule</span> </div> <div style="text-align: center; margin-top: 10px;"> <span style="border: 1px solid #ccc; padding: 5px; border-radius: 5px; background-color: #f0f0f0;">◀ Previous</span>      Page 4 of 6      <span style="border: 1px solid #ccc; padding: 5px; border-radius: 5px; background-color: #f0f0f0;">Next ▶</span> </div>
--	--

Schedule Dry allows to prevent the use of water and hence adiabatic operation between 2 times on the same day.

<b>Leaving Fluid Control</b>  <b>Load Limiting</b>  <b>Maintenance</b>	<p><b>Schedule Dry</b></p> <p>Schedule Dry ● Disabled</p> <div style="display: flex; justify-content: space-around; align-items: center;"> <span style="border: 1px solid #0070C0; color: #0070C0; padding: 5px; border-radius: 5px; background-color: #f0f0f0;">Enable</span> <span style="color: green; font-size: small;">● Enabled</span> <span style="border: 1px solid #0070C0; color: #0070C0; padding: 5px; border-radius: 5px; background-color: #f0f0f0;">Disable</span> </div> <div style="text-align: center; margin-top: 10px;"> <span style="border: 1px solid #ccc; padding: 5px; border-radius: 5px; background-color: #f0f0f0;">◀ Previous</span>      Page 5 of 6      <span style="border: 1px solid #ccc; padding: 5px; border-radius: 5px; background-color: #f0f0f0;">Next ▶</span> </div>
--	--

<b>Schedule dry</b>	allows to either enable or disable the feature. If enabled, no water will be used during the times set in the schedule on page 6.
<b>Schedule dry override</b>	if enabled, no water will be used regardless of the schedule on page 6. In addition to the on-screen button, the override can also be enabled with the "ScheduleDryOverride" variable in the BMS communication table.

Schedule Dry allows to program the day times during which this mode becomes active when enabled at page 5.



<b>Leaving Fluid Control</b>	<b>Schedule Dry Schedule</b>
	Mon: 06:00 - 21:00
	Tue: 06:00 - 21:00
	Wed: 06:00 - 21:00
<b>Load Limiting</b>	Thu: 06:00 - 21:00
	Fri: 06:00 - 21:00
<b>Maintenance</b>	Sat: 06:00 - 21:00
	Sun: 06:00 - 21:00
	<input type="button" value="Update Schedule"/>
	<input type="button" value="&lt; Previous"/> Page 6 of 6 <input type="button" value="Next &gt;"/>

## Maintenance

Coil clean allows to reverse the fans for a short period of time in order to blow away any dust that might have collected on the coil fins.

<b>Leaving Fluid Control</b>	<b>Coil Clean</b>
	Coil Clean ● Disabled <input type="button" value="Enable"/>
<b>Load Limiting</b>	Cleaning High Limit Temp <input type="button" value="30"/> °C
<b>Maintenance</b>	Cleaning Low Limit Temp <input type="button" value="20"/> °C
	Coil Clean Duration <input type="button" value="120"/> Sec.
	Time Between Coil Clean <input type="button" value="18"/> Hrs.
	Coil Clean Start Time <input type="button" value="15:30"/> 24-Hr. Time
	<input type="button" value="&lt; Previous"/> Page 1 of 3 <input type="button" value="Next &gt;"/>

<b>Coil clean</b>	allows to either enable or disable the feature. If enabled, the fans will do a daily cycle at a 100% fan speed in reverse direction at the time programmed.
<b>Cleaning high limit temperature</b>	maximum ambient temperature at which the coil cleaning cycle can start. Since the fans run in reverse, they will push warm ambient air over the coils in summer.
<b>Cleaning low limit temperature</b>	minimum ambient temperature at which the coil cleaning cycle can start. Since the fans run at a maximum fan speed, there would be an undercooling and/or coil freezing risk if allowed to become too low.
<b>Coil clean duration</b>	time in seconds the coil cleaning cycle lasts

<b>Time between coil clean</b>	number of hours between coil cleaning cycles
<b>Coil clean start time</b>	time of the day when the coil cleaning cycle will start



Pad clean allows to force adiabatic operation for a period of time to rinse any dust that might have collected on the pads.

**Leaving Fluid Control**

**Load Limiting**

**Maintenance**

**Pad Clean**

Pad Clean  
● Disabled      **Enable**

Pad Clean Duration      **12** Sec.

Time Between Pad Cleans      **10** Hrs.

Pad Clean Start Time      **14:30** 24-Hr. Time

[◀ Previous](#)    Page 2 of 3    [Next ▶](#)

<b>Pad clean</b>	allows to either enable or disable the feature. If enabled, the pads will be rinsed at the time programmed.
<b>Pad clean duration</b>	time in seconds the pad cleaning cycle lasts.
<b>Time between pad cleans</b>	number of hours between pad cleaning cycles
<b>Pad clean start time</b>	time of the day when the pad cleaning cycle will start, preferably set in the afternoon to take advantage of the increased cooling effect during the warmest period of the day.



# Input & Output

With the parameters that can be set in this menu, the user can read the current status of all available in- and outputs. In addition, some output signals can be forced in a certain position to overrule the default programming.

## Temperatures

Temperatures

Make Up

Pumps

Basin Water Level

Leaving Fluid Temp 35°C

Outside Air Temp 37°C

< Previous Page 1 of 2 Next >

Leaving fluid temperature	process fluid temperature
Outside air temperature	ambient dry bulb temperature

Temperatures

Make Up

Pumps

Basin Water Level

Precool 1 Temp 22°C

Precool 2 Temp 22°C

< Previous Page 2 of 2 Next >

Precool 1/2 temp	depressed dry bulb behind the adiabatic pre-cooler section.
------------------	---



This screen will only be visible if the relevant sensors are installed.

## Make up



Temperatures	Precooler 1: Lag	Precooler 2: Lead
Make Up	● Make Up Valve 1 - Open	● Make Up Valve 2 - Closed
Pumps		
Basin Water Level		
	<	>

Precooler 1/2	indicates which pre-cooler will start first (lead) or last (lag)
Make-up valve 1/2	indicates the state of each valve (open/closed)

## Starts and hours

In this menu the starts and amounts of operating hours can be consulted. Pressing the reset button shall reset the starts and hours for the corresponding device.

A reset can only be done with access level Technician or higher.

Starts and Hours	Starts and Hours
Manual	Precooler 1 Starts: 0 Hours: 0.0 <span style="background-color: #0070C0; color: white; padding: 5px;">Reset</span>
	Precooler 2 Starts: 0 Hours: 0.0 <span style="background-color: #0070C0; color: white; padding: 5px;">Reset</span>
	< Previous Page 1 of 3 Next >

Precooler 1	number starts and amount of operating hours
Precooler 2	number starts and amount of operating hours



Starts and Hours

Starts and Hours

Manual	MUP1 (Make Up Valve 1)	Starts: 1	Hours: 0.0	Reset
	MUP2 (Make Up Valve 2)	Starts: 0	Hours: 0.0	Reset

< >

< Previous

Page 2 of 3

Next >

<b>MUP1</b>	number starts and amount of operating hours for make-up valve 1
<b>MUP2</b>	number starts and amount of operating hours for make-up valve 2

## Manual

In this menu, digital outputs can be controlled manually. This is only available for access level Technician or above.

Starts and Hours

Digital Outputs

Manual	Makeup Valve 1 Open	<input type="button" value="Close"/>	Pump 1 Contact Off	<input type="button" value="Turn On"/>
	Manual Mode	<input type="button" value="Off"/>	Manual Mode	<input type="button" value="On"/>
	Makeup Valve 2 Open	<input type="button" value="Close"/>	Pump 2 Contact Off	<input type="button" value="Turn On"/>
	Manual Mode	<input type="button" value="On"/>	Manual Mode	<input type="button" value="Off"/>

< >

< Previous

Page 1 of 2

Next >

<b>Make up valve 1/2</b>	force either make-up valve on or off
<b>Pump 1/2</b>	force either pump on or off (greyed out and not available for once through units)

**Starts and Hours**

**Digital Outputs**

Drain Valve Open	<b>Close</b>	General Alarm On	<b>Turn Off</b>
Manual Mode	 On	Manual Mode	 Off

< > **< Previous** Page 2 of 2 **Next >**

<b>Drain valve</b>	force the drain valve open or closed
<b>General alarm</b>	force the general alarm contact on or off



## Alarms

This menu allows to get an overview of and clear any existing alarms. All active alarms are displayed with a red font, inactive alarms are displayed in a black font.

For a detailed overview of the different alarms, see chapter 5.

Alarms					
	Time raised	Text			
1	9:57:47.078 AM	Fan 3 Output Stage Overheated			
2	9:57:47.078 AM	Fan 3 Communications Error			
3	9:57:47.078 AM	Fan 3 Three Phase Failure			
4	9:57:42.855 AM	Fan 3 Fan Bad			

<b>Download to USB</b>	pressing the download button (USB stick with down arrow icon) will verify if a USB storage device is present in the PLC and download the alarm log (a progress bar will indicate the status of the process).
<b>Information</b>	pressing the Information button (lower case 'i' in a circle) will display the alarm detail page of the selected alarm where the trigger criteria, release criteria and the trouble shooting steps can be consulted (press the back button in the top right corner to return).
<b>Acknowledge current</b>	pressing the 'single checkmark' will clear the selected alarm
<b>Acknowlegde all</b>	pressing the 'multi-checkmark' will clear all active alarms and change the text from a red to a black font. A pop-up window will ask for a confirmation first

## Settings

With the parameters that can be set in this menu, the user can configure the behaviour of the unit.

## SET UP



<b>Setup</b>	Language	English
<b>Software Version</b>	Units	SI
<b>Technician</b>	Date Format	DD/MM/YYYY
<b>Manufacturing</b>	Date	4 2 2022 SetDate
<b>Engineering</b>	< Previous Page 1 of 3 Next >	

<b>Language</b>	determines the interface language
<b>Units</b>	determines the units of measurements for the different variables. This can be set to either SI or imperial
<b>Date format</b>	determines in what order the day, month and year are shown. This can be set at MM/DD/YYYY, DD/MM/YYYY or YYYY/MM/DD
<b>Date</b>	allows to change the current date (in the format chosen above).

<b>Setup</b>	24 Hour Time	9 : 56 : 32	SetTime
<b>Software Version</b>	Daylight Savings	Turn On	
<b>Technician</b>	BMS Protocol	Modbus RTU Configure	
<b>Manufacturing</b>	Touchscreen	Calibrate	
<b>Engineering</b>	< Previous Page 2 of 3 Next >		

<b>24 hour time</b>	allows to change the current time
<b>Daylight savings</b>	enable or disable daylight savings time
<b>BMS protocol</b>	select and configure the BMS bus system
<b>Touchscreen</b>	calibrate the screen



For more information on your BMS protocol, check the Protocols Manual.

Setup	IP Config
Software Version	IP Address 192.168.0.100
Technician	Subnet Mask 255.255.255.0
Manufacturing	Default Gateway 0.0.0.0
Engineering	* Note: Adjustments to IP Address above will affect the BMS Protocol  <a href="#">◀ Previous</a> Page 3 of 3 <a href="#">Next ▶</a>

<b>IP address</b>	set the correct value (in IPv4 format)
<b>Subnet mask</b>	set the correct value (in IPv4 format)
<b>Default gateway</b>	set the correct value (in IPv4 format)

## SOFTWARE VERSION



<b>Setup</b>	Software Version T3.X.Y.BBBB	OS Version Windows 10 Enterprise LTSC Build 1809
<b>Software Version</b>	Control Version X.Y	
<b>Technician</b>	TwinCAT Version V3.1.4024.12	
<b>Manufacturing</b>	TwinCAT HMI Server Version 1.12.742.5	
<b>Engineering</b>		<a href="#">&lt; Previous</a> Page 1 of 3 <a href="#">Next &gt;</a>

<b>Software version</b>	indicates the current version
<b>Control version</b>	indicates the current version
<b>TwinCAT version</b>	indicates the current version
<b>TwinCAT HMI server version</b>	indicates the current version
<b>OS version</b>	indicates the current version

<b>Setup</b>	Config File:  Config_0.txt	<a href="#">Load</a>
<b>Software Version</b>		
<b>Technician</b>	Export Config	<a href="#">Export</a>
<b>Manufacturing</b>		
<b>Engineering</b>		<a href="#">&lt; Previous</a> Page 2 of 3 <a href="#">Next &gt;</a>

<b>Config file</b>	load a config file from a USB storage device. The file needs to be a text file stored as “E:\BAC\Config\...”
<b>Export config</b>	export the current settings

# ALARMS AND WARNINGS OVERVIEW

## Alarms overview

An overview of all the possible alarms

### Low leaving fluid temperature alarm

Parameter	Condition
Trigger criteria	<p>The unit shall issue the alarm when any of the following are true:</p> <ul style="list-style-type: none"> <li>• Control Type = LFT Ctrl AND Fluid Type = Water AND Leaving Fluid Temperature <math>\leq</math> 10 °C for 3 consecutive seconds</li> <li>• Control Type = LFT Ctrl AND Fluid Type = Glycol AND Leaving Fluid Temperature <math>\leq</math> 7.2 °C for 3 consecutive seconds</li> </ul>
Release criteria	<p>The unit shall release the alarm when any of the following is true:</p> <ul style="list-style-type: none"> <li>• Control Type = LFT Ctrl AND Fluid Type = Water AND Leaving Fluid Temperature <math>&gt;</math> 13 °C for 3 consecutive seconds</li> <li>• Control Type = LFT Ctrl AND Fluid Type = Glycol AND Leaving Fluid Temperature <math>&gt;</math> 10.2 °C for 3 consecutive seconds</li> <li>• Control Type <math>\sim=</math> LFT Ctrl</li> </ul>
Troubleshooting	<ul style="list-style-type: none"> <li>• Check Leaving Fluid Temperature sensor installation</li> <li>• Check Leaving Fluid Temperature sensor and wiring</li> </ul>
General alarm DO	True
Effect	Emergency flag = True

## Leaving fluid temperature sensor alarm



Parameter	Condition
Trigger criteria	The unit shall issue the alarm when any of the following are true: <ul style="list-style-type: none"> <li>• Control Type = LFT Ctrl</li> <li>• Leaving Fluid Temperature &gt; 90 °C OR</li> <li>Leaving Fluid Temperature &lt; -50 °C OR</li> <li>EL3208-0010 Channel 2 cable break detected</li> </ul>
Release criteria	The unit shall release the alarm when any of the following is true: <ul style="list-style-type: none"> <li>• Control Type ~= LFT Ctrl</li> <li>• Leaving Fluid Temperature ≤ 87 °C</li> <li>• Leaving Fluid Temperature ≥ -47 °C</li> <li>• EL3208-0010 Channel 2 cable break undetected</li> </ul>
Troubleshooting	<ul style="list-style-type: none"> <li>• Check Leaving Fluid Temperature sensor installation</li> <li>• Check Leaving Fluid Temperature sensor and wiring</li> </ul>
General alarm DO	True
Effect	Emergency flag = True

## Outside air temperature sensor

Parameter	Condition
Trigger criteria	The unit shall issue the alarm when any of the following are true: <ul style="list-style-type: none"> <li>• Outside Air Temperature &lt; -30 °C for 3 consecutive seconds</li> <li>• Outside Air Temperature &gt; 60 °C for 3 consecutive seconds</li> <li>• EL3208-0010 Channel 2 cable break detected</li> </ul>
Release criteria	The unit shall release the alarm when any of the following is true: <ul style="list-style-type: none"> <li>• Outside Air Temperature ≥ -27 °C for 3 consecutive seconds AND</li> <li>Outside Air Temperature ≤ 57 °C for 3 consecutive seconds</li> <li>• EL3208-0010 Channel 2 cable break is not detected</li> </ul>
Troubleshooting	<ul style="list-style-type: none"> <li>• Check Outside Air Temperature sensor installation</li> <li>• Check Outside Air Temperature sensor and wiring</li> </ul>
General alarm DO	True
Effect	Disable Water = True



## Precooler 1 Temperature Sensor Alarm

The following shall be displayed only if the Precooler Temperature Sensor is Enabled.

Parameter	Condition
Trigger criteria	<p>The unit shall issue the alarm when any of the following are true:</p> <ul style="list-style-type: none"><li>• Precooler Temp Sensor is enabled</li><li>• Precooler 1 Temperature &gt; 60 °C</li><li>• Precooler 1 Temperature &lt; -30 °C</li><li>• EL3208-0010 Channel 4 cable break detected</li></ul>
Release criteria	<p>The unit shall release the alarm when all of the following is true:</p> <ul style="list-style-type: none"><li>• Precooler Temp Sensor is disabled</li><li>• Precooler 1 Temperature ≤ 57 °C</li><li>• Precooler 1 Temperature ≥ -27 °C</li><li>• EL3208-0010 Channel 4 cable break undetected</li></ul>
Troubleshooting	<ul style="list-style-type: none"><li>• Check Precooler 1 Temperature sensor installation</li><li>• Check Precooler 1 Temperature sensor and wiring</li></ul>
General alarm DO	True
Effect	N/A

## Precooler 2 Temperature Sensor Alarm

The following shall be displayed only if the Precooler Temperature Sensor is Enabled.

Parameter	Condition
Trigger criteria	<p>The unit shall issue the alarm when any of the following are true:</p> <ul style="list-style-type: none"><li>• Precooler Temp Sensor is enabled</li><li>• Precooler 2 Temperature &gt; 60 °C</li><li>• Precooler 2 Temperature &lt; -30 °C</li><li>• EL3208-0010 Channel 4 cable break detected</li></ul>
Release criteria	<p>The unit shall release the alarm when all of the following is true:</p> <ul style="list-style-type: none"><li>• Precooler Temp Sensor is disabled</li><li>• Precooler 2 Temperature ≤ 57 °C</li><li>• Precooler 2 Temperature ≥ -27 °C</li><li>• EL3208-0010 Channel 4 cable break undetected</li></ul>
Troubleshooting	<ul style="list-style-type: none"><li>• Check Precooler 1 Temperature sensor installation</li><li>• Check Precooler 1 Temperature sensor and wiring</li></ul>
General alarm DO	True
Effect	N/A

## Entering Fluid Temperature Sensor Alarm

The following shall be displayed only if the Entering Fluid Temperature Sensor is Enabled.



Parameter	Condition
Trigger criteria	The unit shall issue the alarm when any of the following are true: <ul style="list-style-type: none"><li>• Entering Fluid Temperature Sensor is enabled</li><li>• Entering Fluid Temperature &gt; 90 °C</li><li>• Entering Fluid Temperature &lt; -50 °C</li><li>• EL3208-0010 Channel 3 cable break detected</li></ul>
Release criteria	The unit shall release the alarm when all of the following is true: <ul style="list-style-type: none"><li>• Entering Fluid Temperature Sensor is disabled</li><li>• Entering Fluid Temperature ≤ 87 °C</li><li>• Entering Fluid Temperature ≥ -47 °C</li><li>• EL3208-0010 Channel 3 cable break undetected</li></ul>
Troubleshooting	<ul style="list-style-type: none"><li>• Check Entering Fluid Temperature sensor installation</li><li>• Check Entering Fluid Temperature sensor and wiring</li></ul>
General alarm DO	True
Effect	N/A

## Relative Humidity Sensor Alarm

The following shall be displayed only if the Relative Humidity Sensor is Enabled.

Parameter	Condition
Trigger criteria	The unit shall issue the alarm when any of the following are true: <ul style="list-style-type: none"><li>• Humidity sensor = Enabled</li><li>• OARH Current ≤ 3 mA</li></ul>
Release criteria	The unit shall release the alarm when all of the following is true: <ul style="list-style-type: none"><li>• Humidity sensor = Disabled</li><li>• OARH Current &gt; 3.7 mA</li></ul>
Troubleshooting	<ul style="list-style-type: none"><li>• Check Humidity sensor installation</li><li>• Check Humidity sensor and wiring</li></ul>
General alarm DO	True
Effect	N/A



## All fans offline / Emergency stop alarm

Parameter	Condition
Trigger criteria	The unit shall issue the alarm when any of the following are true: • All fans time out Modbus communications
Release criteria	The unit shall release the alarm when any of the following is true: • Any fan regains Modbus communications
Troubleshooting	• Check Emergency Stop button • Check Fan Modbus wiring between control panel and fan 1
General alarm DO	True
Effect	Disable Water = True

## Low customer input current alarm

Parameter	Condition
Trigger criteria	The unit shall issue the alarm when all of the following are true: • Control Type = Customer Input • Customer Input Type = 4 – 20 mA • Customer Input Current Signal (EL3014-2) ≤ 3 mA
Release criteria	The unit shall release the alarm when any of the following is true: • Control Type = Customer Input AND Customer Input Type = 4 – 20 mA AND Customer Input Current Signal (EL3014-2) > 3 mA • Control Type ~= Customer Input • Customer Input Type ~= 4 – 20 mA
Troubleshooting	• Check Customer Input wiring • Verify proper software setup
General alarm DO	True
Effect	Emergency Mode = Active

## High leaving fluid temperature alarm

Parameter	Condition
Trigger criteria	The unit shall issue the alarm when all of the following are true: • Control Type == LFT Control • LFT > 85.0 °C
Release criteria	The unit shall release the alarm when any of the following is true: • Control Type != LFT Control AND LFT <= 82.0 °C • Control Type != LFT Control

Parameter	Condition
Troubleshooting	<ul style="list-style-type: none"> <li>Check fluid temperatures elsewhere in the loop</li> <li>Check leaving fluid temperature sensor</li> </ul>
General alarm DO	True
Effect	N/A

## Fan X offline

Parameter	Condition
Trigger criteria	The unit shall issue the alarm when all of the following are true: <ul style="list-style-type: none"> <li>Fan X times out Modbus communications</li> </ul>
Release criteria	The unit shall release the alarm when any of the following is true: <ul style="list-style-type: none"> <li>Fan X regains Modbus communications</li> </ul>
Troubleshooting	Check Fan X's circuit breaker in control panel
General alarm DO	True
Effect	N/A

## Fan X DV-link undervoltage

Parameter	Condition
Trigger criteria	Triggered by fan X
Release criteria	Released by fan X
Troubleshooting	<ul style="list-style-type: none"> <li>Check power supply to unit</li> <li>Contact BAC support</li> </ul>
General alarm DO	True
Effect	N/A

## Fan X position sensor calibration error

Parameter	Condition
Trigger criteria	Triggered by fan X
Release criteria	Released by fan X
Troubleshooting	Contact BAC Support
General alarm DO	True
Effect	N/A



## Fan X speed limit exceeded

Parameter	Condition
Trigger criteria	Triggered by fan X
Release criteria	Released by fan X
Troubleshooting	• Contact BAC Support
General alarm DO	True
Effect	N/A

## Fan X motor blocked

Parameter	Condition
Trigger criteria	Triggered by fan X
Release criteria	Released by fan X
Troubleshooting	• Inspect Fan X and ensure there are no obstructions
General alarm DO	True
Effect	N/A

## Fan X motor hall sensor error

Parameter	Condition
Trigger criteria	Triggered by fan X
Release criteria	Released by fan X
Troubleshooting	• Contact BAC Support
General alarm DO	True
Effect	N/A

## Fan X motor overheating

Parameter	Condition
Trigger criteria	Triggered by fan X
Release criteria	Released by fan X
Troubleshooting	• Contact BAC Support
General alarm DO	True
Effect	N/A

## Fan X fan bad (general error)



Parameter	Condition
Trigger criteria	Triggered by fan X
Release criteria	Released by fan X
Troubleshooting	<ul style="list-style-type: none"><li>Contact BAC Support</li></ul>
General alarm DO	True
Effect	N/A

## Fan X communication error

Parameter	Condition
Trigger criteria	Triggered by fan X
Release criteria	Released by fan X
Troubleshooting	<ul style="list-style-type: none"><li>Check Fan X communication wiring</li><li>Check Fan X communication shielding</li><li>Contact BAC Support</li></ul>
General alarm DO	True
Effect	N/A

## Fan X output stage overheating

Parameter	Condition
Trigger criteria	Triggered by fan X
Release criteria	Triggered by fan X
Troubleshooting	<ul style="list-style-type: none"><li>Contact BAC Support</li></ul>
General alarm DO	True
Effect	N/A

## Fan X phase failure

Parameter	Condition
Trigger criteria	Triggered by fan X
Release criteria	Released by fan X
Troubleshooting	<ul style="list-style-type: none"><li>Check power supply to unit</li><li>Contact BAC Support</li></ul>



Parameter	Condition
General alarm DO	True
Effect	N/A

### Fan X Over Voltage

Parameter	Condition
Trigger criteria	Triggered by fan X
Release criteria	Released by fan X
Troubleshooting	<ul style="list-style-type: none"><li>• Check power supply to unit</li><li>• Contact BAC Support</li></ul>
General alarm DO	True
Effect	N/A

### Fan X Watchdog Failure

Parameter	Condition
Trigger criteria	Triggered by fan X
Release criteria	Released by fan X
Troubleshooting	Contact BAC Support
General alarm DO	True
Effect	N/A

### Fan X Hardware Overcurrent

Parameter	Condition
Trigger criteria	Triggered by fan X
Release criteria	Released by fan X
Troubleshooting	Contact BAC Support
General alarm DO	True
Effect	N/A

Parameter	Condition
Trigger criteria	Triggered by fan X
Release criteria	Released by fan X
Troubleshooting	Contact BAC Support
General alarm DO	True
Effect	N/A

## Alarm codes

The status of different alarms is also available through the BMS system for which the following codes are used.

Alarm codes are enumerations porting a number code to a specific alarm. These codes shall be used in the Data Logging and BMS Communication to effectively communicate active alarms.

### UNIT ALARM CODE

Alarm Code	Unit Alarm
0	No alarm
5	Low Leaving Fluid Temperature
9	Make Up 1 Alarm
10	Make Up 2 Alarm
12	Leaving Fluid Temperature Sensor Alarm
13	Outside Air Temperature Sensor Alarm
14	All Fans Offline / E-Stop Alarm
17	Low Customer Input Current
19	Precooler 1 Temperature Sensor Alarm
20	Precooler 2 Temperature Sensor Alarm
21	Entering Fluid Temperature Sensor Alarm
22	Relative Humidity Sensor Alarm



## FAN ALARM CODE

Alarm Code	Fan Alarm
0	No Fan Alarm
1	Fan 1 Offline
2	Fan 1 DC-link Undervoltage
3	Fan 1 Position Sensor Cal Error
4	Fan 1 Speed Limit Exceeded
5	Fan 1 Motor Blocked
6	Fan 1 Hall Sensor Error
7	Fan 1 Motor Overheating
8	Fan 1 Fan Bad (General Error)
9	Fan 1 Communication Error
10	Fan 1 Output Stage Overheating
11	Fan 1 Phase Failure
12	Fan 2 Offline
13	Fan 2 DC-link Undervoltage
14	Fan 2 Position Sensor Cal Error
15	Fan 2 Speed Limit Exceeded
16	Fan 2 Motor Blocked
17	Fan 2 Hall Sensor Error
18	Fan 2 Motor Overheating
19	Fan 2 Fan Bad (General Error)
20	Fan 2 Communication Error
21	Fan 2 Output Stage Overheating
22	Fan 2 Phase Failure
23	Fan 3 Offline
24	Fan 3 DC-link Undervoltage
25	Fan 3 Position Sensor Cal Error
26	Fan 3 Speed Limit Exceeded
27	Fan 3 Motor Blocked
28	Fan 3 Hall Sensor Error
29	Fan 3 Motor Overheating
30	Fan 3 Fan Bad (General Error)
31	Fan 3 Communication Error
32	Fan 3 Output Stage Overheating
33	Fan 3 Phase Failure

Alarm Code	Fan Alarm
34	Fan 4 Offline
35	Fan 4 DC-link Undervoltage
36	Fan 4 Position Sensor Cal Error
37	Fan 4 Speed Limit Exceeded
38	Fan 4 Motor Blocked
39	Fan 4 Hall Sensor Error
40	Fan 4 Motor Overheating
41	Fan 4 Fan Bad (General Error)
42	Fan 4 Communication Error
43	Fan 4 Output Stage Overheating
44	Fan 4 Phase Failure
45	Fan 5 Offline
46	Fan 5 DC-link Undervoltage
47	Fan 5 Position Sensor Cal Error
48	Fan 5 Speed Limit Exceeded
49	Fan 5 Motor Blocked
50	Fan 5 Hall Sensor Error
51	Fan 5 Motor Overheating
52	Fan 5 Fan Bad (General Error)
53	Fan 5 Communication Error
54	Fan 5 Output Stage Overheating
55	Fan 5 Phase Failure
56	Fan 6 Offline
57	Fan 6 DC-link Undervoltage
58	Fan 6 Position Sensor Cal Error
59	Fan 6 Speed Limit Exceeded
60	Fan 6 Motor Blocked
61	Fan 6 Hall Sensor Error
62	Fan 6 Motor Overheating
63	Fan 6 Fan Bad (General Error)
64	Fan 6 Communication Error
65	Fan 6 Output Stage Overheating
66	Fan 6 Phase Failure
67	Fan 7 Offline
68	Fan 7 DC-link Undervoltage
69	Fan 7 Position Sensor Cal Error
70	Fan 7 Speed Limit Exceeded



Alarm Code	Fan Alarm
71	Fan 7 Motor Blocked
72	Fan 7 Hall Sensor Error
73	Fan 7 Motor Overheating
74	Fan 7 Fan Bad (General Error)
75	Fan 7 Communication Error
76	Fan 7 Output Stage Overheating
77	Fan 7 Phase Failure
78	Fan 8 Offline
79	Fan 8 DC-link Undervoltage
80	Fan 8 Position Sensor Cal Error
81	Fan 8 Speed Limit Exceeded
82	Fan 8 Motor Blocked
83	Fan 8 Hall Sensor Error
84	Fan 8 Motor Overheating
85	Fan 8 Fan Bad (General Error)
86	Fan 8 Communication Error
87	Fan 8 Output Stage Overheating
88	Fan 8 Phase Failure
89	Fan 9 Offline
90	Fan 9 DC-link Undervoltage
91	Fan 9 Position Sensor Cal Error
92	Fan 9 Speed Limit Exceeded
93	Fan 9 Motor Blocked
94	Fan 9 Hall Sensor Error
95	Fan 9 Motor Overheating
96	Fan 9 Fan Bad (General Error)
97	Fan 9 Communication Error
98	Fan 9 Output Stage Overheating
99	Fan 9 Phase Failure
100	Fan 10 Offline
101	Fan 10 DC-link Undervoltage
102	Fan 10 Position Sensor Cal Error
103	Fan 10 Speed Limit Exceeded
104	Fan 10 Motor Blocked
105	Fan 10 Hall Sensor Error
106	Fan 10 Motor Overheating
107	Fan 10 Fan Bad (General Error)

Alarm Code	Fan Alarm
108	Fan 10 Communication Error
109	Fan 10 Output Stage Overheating
110	Fan 10 Phase Failure
111	Fan 11 Offline
112	Fan 11 DC-link Undervoltage
113	Fan 11 Position Sensor Cal Error
114	Fan 11 Speed Limit Exceeded
115	Fan 11 Motor Blocked
116	Fan 11 Hall Sensor Error
117	Fan 11 Motor Overheating
118	Fan 11 Fan Bad (General Error)
119	Fan 11 Communication Error
120	Fan 11 Output Stage Overheating
121	Fan 11 Phase Failure
122	Fan 12 Offline
123	Fan 12 DC-link Undervoltage
124	Fan 12 Position Sensor Cal Error
125	Fan 12 Speed Limit Exceeded
126	Fan 12 Motor Blocked
127	Fan 12 Hall Sensor Error
128	Fan 12 Motor Overheating
129	Fan 12 Fan Bad (General Error)
130	Fan 12 Communication Error
131	Fan 12 Output Stage Overheating
132	Fan 12 Phase Failure
133	Fan 13 Offline
134	Fan 13 DC-link Undervoltage
135	Fan 13 Position Sensor Cal Error
136	Fan 13 Speed Limit Exceeded
137	Fan 13 Motor Blocked
138	Fan 13 Hall Sensor Error
139	Fan 13 Motor Overheating
140	Fan 13 Fan Bad (General Error)
141	Fan 13 Communication Error
142	Fan 13 Output Stage Overheating
143	Fan 13 Phase Failure
144	Fan 14 Offline



Alarm Code	Fan Alarm
145	Fan 14 DC-link Undervoltage
146	Fan 14 Position Sensor Cal Error
147	Fan 14 Speed Limit Exceeded
148	Fan 14 Motor Blocked
149	Fan 14 Hall Sensor Error
150	Fan 14 Motor Overheating
151	Fan 14 Fan Bad (General Error)
152	Fan 14 Communication Error
153	Fan 14 Output Stage Overheating
154	Fan 14 Phase Failure
155	Fan 15 Offline
156	Fan 15 DC-link Undervoltage
157	Fan 15 Position Sensor Cal Error
158	Fan 15 Speed Limit Exceeded
159	Fan 15 Motor Blocked
160	Fan 15 Hall Sensor Error
161	Fan 15 Motor Overheating
162	Fan 15 Fan Bad (General Error)
163	Fan 15 Communication Error
164	Fan 15 Output Stage Overheating
165	Fan 15 Phase Failure
166	Fan 16 Offline
167	Fan 16 DC-link Undervoltage
168	Fan 16 Position Sensor Cal Error
169	Fan 16 Speed Limit Exceeded
170	Fan 16 Motor Blocked
171	Fan 16 Hall Sensor Error
172	Fan 16 Motor Overheating
173	Fan 16 Fan Bad (General Error)
174	Fan 16 Communication Error
175	Fan 16 Output Stage Overheating
176	Fan 16 Phase Failure
177	Fan 17 Offline
178	Fan 17 DC-link Undervoltage
179	Fan 17 Position Sensor Cal Error
180	Fan 17 Speed Limit Exceeded
181	Fan 17 Motor Blocked

Alarm Code	Fan Alarm
182	Fan 17 Hall Sensor Error
183	Fan 17 Motor Overheating
184	Fan 17 Fan Bad (General Error)
185	Fan 17 Communication Error
186	Fan 17 Output Stage Overheating
187	Fan 17 Phase Failure
188	Fan 18 Offline
189	Fan 18 DC-link Undervoltage
190	Fan 18 Position Sensor Cal Error
191	Fan 18 Speed Limit Exceeded
192	Fan 18 Motor Blocked
193	Fan 18 Hall Sensor Error
194	Fan 18 Motor Overheating
195	Fan 18 Fan Bad (General Error)
196	Fan 18 Communication Error
197	Fan 18 Output Stage Overheating
198	Fan 18 Phase Failure
199	Fan 1 Over Current
200	Fan 1 Over Voltage
201	Fan 1 Watchdog Failure
202	Fan 1 Hardware Overcurrent
203	Fan 1 MCdsp Dead
204	Fan 2 Over Current
205	Fan 2 Over Voltage
206	Fan 2 Watchdog Failure
207	Fan 2 Hardware Overcurrent
208	Fan 2 MCdsp Dead
209	Fan 3 Over Current
210	Fan 3 Over Voltage
211	Fan 3 Watchdog Failure
212	Fan 3 Hardware Overcurrent
213	Fan 3 MCdsp Dead
214	Fan 4 Over Current
215	Fan 4 Over Voltage
216	Fan 4 Watchdog Failure
217	Fan 4 Hardware Overcurrent
218	Fan 4 MCdsp Dead



Alarm Code	Fan Alarm
219	Fan 5 Over Current
220	Fan 5 Over Voltage
221	Fan 5 Watchdog Failure
222	Fan 5 Hardware Overcurrent
223	Fan 5 MCdsp Dead
224	Fan 6 Over Current
225	Fan 6 Over Voltage
226	Fan 6 Watchdog Failure
227	Fan 6 Hardware Overcurrent
228	Fan 6 MCdsp Dead
229	Fan 7 Over Current
230	Fan 7 Over Voltage
231	Fan 7 Watchdog Failure
232	Fan 7 Hardware Overcurrent
233	Fan 7 MCdsp Dead
234	Fan 8 Over Current
235	Fan 8 Over Voltage
236	Fan 8 Watchdog Failure
237	Fan 8 Hardware Overcurrent
238	Fan 8 MCdsp Dead
239	Fan 9 Over Current
240	Fan 9 Over Voltage
241	Fan 9 Watchdog Failure
242	Fan 9 Hardware Overcurrent
243	Fan 9 MCdsp Dead
244	Fan 10 Over Current
245	Fan 10 Over Voltage
246	Fan 10 Watchdog Failure
247	Fan 10 Hardware Overcurrent
248	Fan 10 MCdsp Dead
249	Fan 11 Over Current
250	Fan 11 Over Voltage
251	Fan 11 Watchdog Failure
252	Fan 11 Hardware Overcurrent
253	Fan 11 MCdsp Dead
254	Fan 12 Over Current
255	Fan 12 Over Voltage

Alarm Code	Fan Alarm
256	Fan 12 Watchdog Failure
257	Fan 12 Hardware Overcurrent
258	Fan 12 MCdsp Dead
259	Fan 13 Over Current
260	Fan 13 Over Voltage
261	Fan 13 Watchdog Failure
262	Fan 13 Hardware Overcurrent
263	Fan 13 MCdsp Dead
264	Fan 14 Over Current
265	Fan 14 Over Voltage
266	Fan 14 Watchdog Failure
267	Fan 14 Hardware Overcurrent
268	Fan 14 MCdsp Dead
269	Fan 15 Over Current
270	Fan 15 Over Voltage
271	Fan 15 Watchdog Failure
272	Fan 15 Hardware Overcurrent
273	Fan 15 MCdsp Dead
274	Fan 16 Over Current
275	Fan 16 Over Voltage
276	Fan 16 Watchdog Failure
277	Fan 16 Hardware Overcurrent
278	Fan 16 MCdsp Dead
279	Fan 17 Over Current
280	Fan 17 Over Voltage
281	Fan 17 Watchdog Failure
282	Fan 17 Hardware Overcurrent
283	Fan 17 MCdsp Dead
284	Fan 18 Over Current
285	Fan 18 Over Voltage
286	Fan 18 Watchdog Failure
287	Fan 18 Hardware Overcurrent
288	Fan 18 MCdsp Dead

# FURTHER ASSISTANCE & INFORMATION

## More information

### REFERENCE LITERATURE

- Eurovent 9-5 (6) Recommended Code of Practice to keep your Cooling System efficient and safe. Eurovent/Cecomaf, 2002, 30p.
- Guide des Bonnes Pratiques, Legionella et Tours Aéroréfrigérantes. Ministères de l'Emploi et de la Solidarité, Ministère de l'Economie des Finances et de l'Industrie, Ministère de l'Environnement, Juin 2001, 54p.
- Voorkom Legionellose. Ministerie van de Vlaamse Gemeenschap. December 2002, 77p.
- Legionnaires' Disease. The Control of Legionella Bacteria in Water Systems. Health & Safety Commission. 2000, 62p.
- Hygienische Anforderungen an raumluftechnische Anlagen. VDI 6022.

### INTERESTING WEBSITES

Baltimore Aircoil Company	<a href="http://www.BaltimoreAircoil.com">www.BaltimoreAircoil.com</a>
BAC Service website	<a href="http://www.BACservice.eu">www.BACservice.eu</a>
Eurovent	<a href="http://www.eurovent-certification.com">www.eurovent-certification.com</a>
European Working Group on Legionella Infections (EWGLI)	<a href="http://EWGLI">EWGLI</a>
ASHRAE	<a href="http://www.ashrae.org">www.ashrae.org</a>
Uniclima	<a href="http://www.uniclima.fr">www.uniclima.fr</a>
Association des Ingénieurs et techniciens en Climatique, Ventilation et Froid	<a href="http://www.aicvf.org">www.aicvf.org</a>
Health and Safety Executive	<a href="http://www.hse.gov.uk">www.hse.gov.uk</a>

### ORIGINAL DOCUMENTATION



This manual is originally made in English. Translations are provided for your convenience. In the event of discrepancies, the English original text shall prevail over the translation.

## The service expert for BAC equipment

We offer tailored services and solution for BAC cooling towers and equipment.

- Original spare parts and fill -for an efficient, safe and year round reliable operation.
- Service solutions - preventive maintenance, repairs, refurbishments, cleaning and disinfection for reliable trouble-free operation.
- Upgrades and new technologies - save up energy and improve maintenance by upgrading your system.
- Water treatment solutions - equipment for controlling corrosion scaling and proliferation of bacteria.

For more details, contact your local BAC representative for further information and specific assistance at  
[www.BACservice.eu](http://www.BACservice.eu)











COOLING TOWERS

---

CLOSED CIRCUIT COOLING TOWERS

---

ICE THERMAL STORAGE

---

EVAPORATIVE CONDENSERS

---

HYBRID PRODUCTS

---

PARTS, EQUIPMENTS & SERVICES

BLUE by nature  
GREEN at heart



[www.BaltimoreAircoil.com](http://www.BaltimoreAircoil.com)

[Europe@BaltimoreAircoil.com](mailto:Europe@BaltimoreAircoil.com)

Please refer to our website for local contact details.